565-0593 565-0594 421-1400

DALLAS LABORATORIES, INC.

CONSULTANTS AND TECHNOLOGISTS

ANALYTICAL AND RESEARCH CHEMISTS —

CHEMICAL ENGINEERS — PETROLEUM ENGINEERS

MEMBER\$

AMERICAN INSTITUTE OF CHEMICAL ENGINEERS NATIONAL SOCIETY OF PROFESSIONAL ENGINEERS TEXAS SOCIETY OF PROFESSIONAL ENGINEERS ASM INTERNATIONAL SOCIETY OF PETROLEUM ENGINEERS OF AIME

P. O. BOX 152837 1323 WALL ST.

REPORT

DALLAS, TEXAS 75315

MEMBERS

AMERICAN CHEMICAL SOCIETY
AMERICAN SOCIETY FOR TESTING MATERIAL
AMERICAN NATIONAL STANDARDS INSTITUTE
AMERICAN SOCIETY FOR QUALITY CONTROL

Submitted by:

Tiger Drylac USA 1100 Commons Blvd Reading, PA 19605

Attn: Burkhard Maier

Date: May 11, 2007

Report No. 38408-4

Sample:

Coated aluminum:

Extrusions

Paint:

058 MATT Metallic

Production Date:

Unknown

Cure:

Unknown

Pre-treatment:

Unknown

Drawing:

N/A

A. PROCEDURE

Submitted sample was tested for informational purposes according to AAMA 2604-05, "Voluntary Specification, Performance Requirements and Test procedures for High Performance Organic Coatings on Aluminum Extrusions and Panels," Section 7.1 through 7.8.2, with the following results:

B. REPORT

<u>Test</u>	Results	AAMA 2604-05 Specification Requirements
7.1 Color Uniformity	Standard	Standard
7.2 Specular Gloss	3.33	As reported
6.3 Dry Film Hardness	Pass F	F hardness and no film rupture
7.4 Film Adhesion 7.4.1.1 Dry	Pass	No Loss of Adhesion
7.4.1.2 Wet	Pass	No Loss of Adhesion
7.4.1.3 Boiling Water	Pass	No removal of film from substrate

<u>Test</u>	Results	AAMA 2604-05 Specification Requirements
7.5 Impact Resistance	Pass	No removal of film from substrate
7.6 Abrasion Resistance	Pass (60L=20 ACV)	ACV 20 minimum
7. Chemical Resistance		
7.7.1 Muratic Acid	Pass	No Blistering or Visible Change
7.7.2 Mortar	Pass (ΔE= 0.24)	No Blistering or Visible Change
7.7.3 Nitric Acid	Pass	Hunter Delta E=5 maximum
7.7.4 Detergent	Pass	No Film Adhesion Loss or Visible Change
7.7.5 Window Cleaner Resistance	Pass	No blistering or noticeable change in appearance and no film loss
6.7 Corrosion Resistance		
7.8.1 Humidity	Pass (no blisters)	Not greater than Few & No. 8
7.8.2 Salt spray	Pass	
Scribe	10	7 Minimum rating
Field	10	8 Minimum rating
Date Testing Started:	1-10-07	

Testing Conducting At: Dallas Laboratories, Inc., 1323 Wall St., Dallas, Texas 75215.

n/a (informational)

5-8-07

The test results indicate that the sample tested is in compliance with all of the performance requirements of AAMA 2604-05 for High Performance Organic Coatings on Aluminum Extrusions and Panels, except for section 7.9 WEATHERING which must be furnished by the coating supplier for full compliance to AAMA 2604-05 as specified by AAMA.

DALLAS LABORATORIES, INC.

Kevan W. Jones, Vice President

Analyst: GF KWJ/sc

Date Testing Completed:

Sampled by: